

DANESC™

Development and Application of the National Electrical Safety Code

1.0 Day Major Changes in the 2012 NESC

1.0 DA-MC

Start at 8:00am

- ◆ **Section 1—Introduction:** American National Standard, 010A, 010B, 010C, Figure 011-1, 011C1, 011C2, 013A2c, 013B2, 014A2, 015D, 016
- ◆ **Section 2—Definitions:** Area lighting, delivery point, exclusive control of utility, premises wiring, service point, utility, utilization equipment, public utility, private utility, authorized person, exclusive control, premises, supervised installation, clearance, vertical conductor, effectively grounded neutral conductor, communication line in supply space, joint-use lines, vault, lateral conductor, effectively grounded, supported facility
- ◆ **Section 9—Grounding Methods:** 091, 093D, 094B7, 099B
- ◆ **Part 1—Electric Supply Stations:** 110B2, 111A, Table 111-1, 114-Exception, 124A1, 124A3, 124D
- ◆ **Part 2—Overhead:** 214A4, 214A5, 215C1, 215C2, 215C3, 215C4, 215C5, 215C6, 217A1a, 217A2b, 217A4, 218A1, 230A3, 230A4, 230B, Figure 230-1, Table 230-1, Table 230-2, Table 232-1, 233B, 234B, 234C, 234C3, 234C, Table 234-1 & Key Footnotes, 235B1b, 235C, Table 235-5 Footnotes, 235C2, 235G, 235G3, 235H2, Table 235-6, 238A, Table 242-1, 250B, Table 250-1, 250C2, 253, Table 253-1 & Footnotes, Table 253-2, 260A1, 261B, 261H1b, Table 277-1, 279A1b
- ◆ **Part 3—Underground:** Section 32 Note 2, 323E5, 350F&G, 352A2, 352D1&2, Table 352-1, 354A2, 380D-Exception 2
- ◆ **Part 4—Work Rules:** 410A3, Table 410-2, Table 410-3, 420K8, 421A6, 422A2, 431C, Table 431-1, 441, 441A1, 441A4, Table 441-1, 444D, 445
- ◆ **Appendixes:** Appendix A-1 Table, Appendix C, Appendix E